

KOPOS KOLÍN a.s. Havlíčkova 432 CZ – 280 94 Kolín IV

## EU DECLARATION OF CONFORMITY No. 3A-EU-22/20-10

In accordance with EU directive 2014/35/EU as amended

We.

KOPOS KOLÍN a. s. Havlíčkova 432 280 94 Kolín IV Czech Republic IČ: 61672971 DIČ: CZ61672971

declare under our sole responsibility that

the product/type:

Electroinstallation pliable conduit LPE-x (series EN) UV stabil and

accessories

2316E/LPE-1 to 2363/LPE-1 according to TP-KO-01/2010 2316E/LPE-2 to 2363/LPE-2 according to TP-KO-02/2010

manufacturer:

KOPOS KOLÍN a.s. Havlíčkova 432, 280 94 Kolín IV, Czech Republic

object of the declaration:

The electroinstallation pliable pipes are intended for installation to the distribution of low voltage. Flexible UV stable pipes to be suitable for outside

installation. The pipes are not self-snuffing.

Material: PE

Temperature resistance: -25°C to +90°C.

Mechanical resistance: LPE-1 320N/5cm: LPE-2 125N/5cm

Ort code according to 61386-1 ed.2: 22423 for LPE-1; 11423 for LPE-2

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation, other legislation and regulations:

| Regulations<br>Of the European<br>Union | Government<br>Regulations   | Standards  | Certificates and Test<br>Reports  | Other technical specification   |
|---|---|--|---|---|
| 2014/35/EU - LVD                        | Law No. 90/2016<br>Coll. as amended<br>Government<br>Regulation No.<br>118/2016 Coll. as<br>amended | ČSN EN 61386-1 ed. 2:09 including amendments (EN 61386- 1:08 including amendments)  ČSN EN 61386- 22:04+A11:11 including amendments (EN 61386- 22:04 including amendments)                             | Test Report No. 602622-01/01 of 20.7.2016  Issued by: Elektrotechnický zkušební ústav, Pod Lisem 129, 171 02 Praha 71, Czech Republic | TP-KO-01/2010<br>TP-KO-02/2010  |
|   |   | ČSN EN 61386-1 ed. 2:09 including amendments (EN 61386- 1:08 including amendments) ČSN EN 61386-22:04 including amendments (EN 61386-22:02 including amendments) (IEC 61386-1:2008, IEC 61386-22:2002) | Internal tests  | Products:<br>2320/LPE-1_HHHxx<br>Meet min. to<br>450N / 5cm for<br>compression. |



## KOPOS KOLÍN a.s. Havlíčkova 432 CZ – 280 94 Kolín IV

| Directive RoHS<br>2011/65/EU as<br>amended | Government<br>Regulation No.<br>481/2012 Sb. | ZP 344/02 –<br>Methodology for the<br>determination of the<br>elements Pb, Cd, Cr,<br>Hg, Br | Test Report No. 601229-01/01 of 4.4.2016  Issued by: Elektrotechnický zkušební ústav, Pod Lisem 129, 171 02 Praha 71, Czech Republic |   |
|--|--|--|--|---|
| Regulation 1907/2006<br>- REACH            |  |  |  | Safety data sheets for used materials                   |
|  |  |  |  | UV stabilized<br>Technical information<br>from supplier |
|  |  |  |  | Products:<br>2320/LPE-1_HHHxx                           |
|  |  |  |  | UV material was<br>added to customer's<br>request       |

By fulfilling the conditions in accordance with these regulations was placed on the product CE marking

Conformity assessment module: MODUL A: Internal production control

Technical documentation of products:

- assembly instructions
- Datasheet
- Catalog for products freely available on http://www.kopos.cz/cs/katalogy
- Internal documents

KOPOS KOLÍN a.s. company is certificated according to the standard ISO 9001:2015, ISO 14001:2015 and ISO 50001:2011 and according to the National program "Safety Enterprise".

Signed for KOPOS KOLÍN a.s.

Place of issue: Kolín, Czech Republic

Date of issue: 23.10.2020

Ing. Jana Dejmková

Management representative for QMS

Mynhora

KOPOS KOLÍN a.s. ÚSEK ŘÍZENÍ SYSTÉMU JAKOSTI